

Certificate of constancy of performance

2391-CPR-18-372

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Mechanically operated locks, latches and locking plates

for use with an appropriate door closing device on fire and/or smoke control doors to fulfil the self-closing requirement of such doors, and thereafter to ensure that the door remains shut. With product name, conditions and performance as specified on page 2 in this certificate;

placed on the market under the name or trade mark of

ASSA ABLOY Opening Solutions Sweden AB

Kungsgatan 71, SE-631 05 Eskilstuna, Sweden

and produced in the manufacturing plant(s)

19-258, 19-259

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12209:2003, EN 12209:2003/AC:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 2019-08-21 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Stockholm 2019-08-21



Mårten Wallén
Managing Director

Svensk Brand- och Säkerhetscertifiering AB, Tegeluddsvägen 100, SE-115 28 Stockholm, Sweden



Certificate of constancy of performance

Product name

ASSA Modul		
565/765	504	6498
560/760	506	1398-28
562/762	509	5761
1560/1760	1520	8768
6585/6785	8560/8760	564
2000	8561/8761	1362-28
7787	1498	13585-28
8765	2565	1361-28

Conditions

Max door weight 200 kg

Performance

Essential characteristic	Requirement clause	Performance
Self-closing ability	5.4.2 Closing force	≤ 15 N
	5.1.2 Return force of latch bolt	$\geq 2,5$ N
Durability of self-closing action	5.3.1 Durability of latch action	200 000 test cycles, 120 N load
Ability to maintain door in closed position, and not contribute to the spread of fire	5.2.1 Resistance to side load on latch bolt	3 kN
	5.5 Suitability for use on fire/smoke doors	Suitable for use on fire/smoke resisting door assemblies